



# TRANSIT FLOOR COVERINGS

H A LATEULERE AND COMPANY (NATAL) (PTY) LTD  
CO REG NO. 1971/012906/07 VAT REG NO. 4010 104 19 0

Transit Floor Coverings is a Level 4 B-BBEE Contributor

PO BOX 8298  
1406 ELANDSFONTEIN  
SOUTH AFRICA

3 BUNDO ROAD  
SEBENZA  
EDENVALE

TELEPHONE 0861 TRANSIT / 0861 872 674  
TELEFAX 086 670 8110  
EMAIL [info@transittiles.com](mailto:info@transittiles.com)  
WEBSITE [www.transittiles.com](http://www.transittiles.com)

20 August 2015

## VR TEST RESULTS FOR TRANSIT CONDUCTIVE / ESD FLOOR TILES

Insulation Continuity Test using a MEGGAR @ 500V

Results reported in Meg-Ohms ( $1 \times 10^6$ )

Test Conducted 20 August 2015

Raw Material Batch Number W0002356

Sample A Transit 300mm x 300mm x 3mm Studded Conductive floor tile

Result Top – 0.33  
Bottom – 0.28  
Middle – 0.28  
Corner to corner – 0.36

Sample B Transit 300mm x 300mm x 3mm Studded Conductive floor tile

Result Top – 0.26  
Bottom – 0.25  
Middle – 0.26  
Corner to corner – 0.34

Sample C Transit 300mm x 300mm x 3mm Studded Conductive floor tile

Result Top – 0.30  
Bottom – 0.28  
Middle – 0.25  
Corner to corner – 0.30

JONATHAN COPE  
DIRECTOR

DIRECTOR : J. COPE